

Ground Line

Coop. Furnishes PVC Pipe up Pole

Coop. Furnishes Schedule 40 PVC Expansion Joint

Customer Stops Pipe 12in. min. above Ground Line

150 ft. Max Straight Ditch Length

3in. Schedule 40 PVC Long Sweep 90 36" radius

Customer supplies 3in. Schedule 40 PVC Electrical Grade (Grey) with rope in pipe


Coop must go into bottom left-hand side

3in. Schedule 40 PVC Expansion Joint

5 ft.

3in. Schedule 40 PVC Long Sweep 90 36" radius

3 ft.

A	 Holmes-Wayne Electric Cooperative, Inc. <small>A Touchstone Energy Cooperative</small>	DWG NAME:
		200 amp Underground Service
SCALE: NONE	DATE: 7-28-2008	SHEET: 1 OF 1