

Ground Line

Coop. Furnishes PVC Pipe up Pole

Coop. Furnishes Schedule 40 PVC Expansion Joint

Customer Stops Pipe 12in. min. above Ground Line

150 ft. Max Straight Ditch Length

3in. Schedule 40 PVC Long Sweep 90 36" radius

Customer supplies 3in. Schedule 40 PVC Electrical Grade (Grey) with rope in pipe

3in. Schedule 40 PVC Long Sweep 90 36" radius

Coop must go into bottom left-hand side


3in. Schedule 40 PVC Expansion Joint

5 ft.

3 ft.

6' Min

Grounds connected to main disconnect panel

A	 Holmes-Wayne Electric Cooperative, Inc. <small>A Southwestern Energy Cooperative</small>	DWG NAME: 200 amp Underground Service
	SCALE: NONE	DATE: 3-26-2024